

Tale/Fax: 011-2301 5399

**SPEED POST/REGISTERED DUE**

Dte Gen Md Accn project  
E-in-C's Branch,  
Integrated HQ of MOD (ARMY)  
Kashmir House, Rajaji Marg,  
New Delhi – 110011

No. 82805/MAP/PH-II/JAL&amp;ADM (AF)/Pkg-6(I)/THU/E8

18 Nov 2010

M/s. \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

**CA No: DGMAP/PH-II/JAL&ADM(AF)/PKG-6 (I) OF 2008-2009 : CONSTRUCTION OF MARRIED ACCOMMODATION AT JALANDHAR AND ADAMPUR.**

1. Reference this HQ letter Nos. 82805/MAP/PH-II/JAL&ADM(AF)/Pkg-6(I)/81/E8 dated 03 Sep 2010, 82805/MAP/PH-II/JAL&ADM(AF)/Pkg-6(I)/94/E8 dated 04 Oct 2010, 82805/MAP/PH-II/JAL&ADM(AF)/Pkg-6(I)/105/E8 dated 02 Nov 2010 & 82805/MAP/PH-II/JAL&ADM(AF)/Pkg-6(I)/110/E8 dated 10 Nov 2010.

2. Amendments / errata to the tender documents for the subject work issued vide this HQ letter under reference are as under:-

<b>Srl No.</b>	<b>Page No.</b>	<b>Reference to item, clause, para, line etc.</b>	<b>Particulars of amendments / errata.</b>
<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>
114	12.	Note No. 5(b), line 1	Insert "stainless steel hooks" after the word "peg sets"
115	13	Note No. 5(g), line 1	Insert "marble rack," after the word "cooking platform"
116	190	Clause 11.3.3.1	Insert "over sub base floor/RCC slab" after the word "3kg/sqm"
117	191	After clause 11.6	Add new clause 11.7 as under: "11.7 <b>FLOORING FOR SERVANT QUARTER / STAIR CASE / LOBBY / MACHINE ROOM, GARBAGE BINS, FIRE CONTROL ROOM &amp; ELECTRIC MAINTENANCE ROOM</b> :- Flooring for servant quarter, stair case, lobby, machine room garbage bins, fire control room & electric maintenance room etc shall be of kota stone or granite stone as shown on drawings."
118	198	After clause 16.15	Add new clause 16.16. as under:- "16.16 <b>GLASS SHELVES CABINET IN DRAWING/ DINNING ROOM</b> : Glass shelves in dinning room shall be provided as per details shown on drawings. All wooden members shall be of 2 <sup>nd</sup> class hard wood fixed to wall with chromium plated screws & rawl plugs of adequate size. Top, bottom & sides members shall be of 18mm thick pre laminated exterior grade particle board. Back of cabinet shall be of 6mm thick BWR apply. Glass for shelf and shutters shall be of 8mm thick float glass, shutters shall be fixed in double aluminium channels with s/s roller blocks. Each glass shutters shall be provided with s/s plate of size 50x25x5 mm thick for hand grip. The edges of glass shall be rounded off. The edges of particle board shall be provided with 6mm thick teak wood edging. All wooden surface except pre laminated surface shall be painted with 2-coats of synthetic enamel point over a coat of primer."

Contd/--

**Amendments / Errata (Contd...)**

<b>1</b>	<b>2</b>	<b>3</b>	<b>4</b>
119	200	Clause 17.11	Delete the existing clause in toto and insert as under in lieu:- "17.11 <b>GLASS TRAY</b> :- Glass shelf/tray shall be provided below looking mirror in each toilet. The thickness of glass for shelf shall be 8 mm thick float glass with rounded edges. The glass shelves shall be fixed with chromium plated brass brackets as shown of drawings. The size of glass tray for officer's DUs shall be 900x120 mm and for JCO's & OR's DUs the size shall be 600x120 mm."
120	343 (R)	a) Srl No. 285, col 7 b) Srl No. 286, col 7 c) Srl No. 287, col 7	For "09/7/2010" Read "10/11/2010" Insert revision date as "10/11/2010" For "6/10/2010" Read "10/11/2010"
121	344	a) Srl No. 288, col 7 b) Srl No. 307, col 7	For "6/10/2010" Read "10/11/2010" Insert revision date as "10/11/2010"
122	356	Amendment Nos 350 & 352	Renumber these amendment as "112" & "113" respectively.
123		Clarification on drawings	Irrespective of what is shown on drawings, in drying out verandah at GF, the wall below grill shall be 115 mm thick of brick masonry built in CM 1:4 all as specified.
124		Drawing No. 119	The frame work for fixed glazing shall be of aluminum anodized & sections to be used shall be of M/s Jindal or equivalent approved make.

3. The revised drawings are enclosed herewith. (05 Nos.)
4. This letter along with enclosure shall form part of the tender documents and shall be returned alongwith tender documents.
5. The date and time for receipt of tender has been changed and shall be received back on **01 Dec 2010** up to **12:30** hrs.

**Enclosure: As above**

Your's faithfully

(Signature of Contractor)  
Dated: \_\_\_\_\_

DEPMC

Jt. Dir (Contracts)  
for Accepting Officer